

PORTABLE APPLIANCE INSPECTION AND TEST RECORD

CHICKEN Van Van 3.

CONTACT NAME & SITE ADDRESS: Ramside Event Catering

CONTRACTORS: TRADING TITLE & ADDRESS: Ramside Hall

TEST EQUIPMENT: Make, Model and Ser. N°: KENTECH KT71

EMPLOYEE UNDERTAKING WORK
NAME (BLOCK CAPITALS): S MCTOY
SIGNATURE:

Room Number (Location)	Appliance Description & Make, etc	Identity N°	VISUAL CHECKS					ELECTRICAL TESTS			Comments	Date of Check	Pass (P) or Fail (F)		
			Class (I, II, etc)	Fuse Rating (A)	Suitability (✓/X)	Plug	Lead	App. casing	Earth Bond Test current (A)	Resistance (Ω)				Insulation Resistance MΩ	mA
CHICKEN VAN	BUILT IN BO FRIIDGE	1	I	13	✓	✓	✓	✓	20	0.07	>20	0.11		3-5-17	P
"	WATER PUMP	2	II	13	✓	✓	✓	✓	20	—	>20	0.04		"	P
"	ROTISSERY	3	I	13	✓	✓	✓	✓	20	0.13	>20	0.17		"	P
"	ROLLER GRILL	4	I	13	✓	✓	✓	✓	20	0.14	>20	0.17		"	P
"	OVEN 1	5	I	13	✓	✓	✓	✓	20	0.07	>20	0.74		"	P
"	OVEN 2	6	I	13	✓	✓	✓	✓	20	0.07	>20	0.91		"	P
"	DRINKS COOLER	7	I	13	✓	✓	✓	✓	20	0.04	>20	0.14		"	P
"	FRIIDGE	8	I	13	✓	✓	✓	✓	20	0.08	>20	0.11		"	P
"	HOT LAMPS	9	I	13	✓	✓	✓	✓	20	0.08	>20	2.01		"	P
"	HOT LAMP	10	I	13	✓	✓	✓	✓	20		>20	2.14		"	P

PORTABLE APPLIANCE INSPECTION AND TEST RECORD

Page of

RECORD N°

ILLY Coffee van **Van 4**

CONTACT NAME & SITE ADDRESS:

Ramside Event Catering

CONTRACTOR'S TRADING TITLE & ADDRESS:

Ramside Hall

TEST EQUIPMENT - Make, Model and Ser. N°:

KENTECH KT 71

EMPLOYEE UNDERTAKING WORK

NAME (BLOCK CAPITALS)
SMEGIV

(SIGNATURE)


Room Number (location)	Appliance Description & Make, etc	Identity N°	VISUAL CHECKS				ELECTRICAL TESTS			Comments	Date of Check	Pass (P) or Fail (F)	
			Class (I, II, etc)	Fuse Rating (A)	Suitability (✓/X)	Plug	Lead	App. casing	Earth Bond Test current (A)				Resistance (Ω)
ILLY	FRIDGE	1	1	13	✓	✓	✓	0.07	0.03	∞	0.31	3-5-17	P
	WATER PUMP	2	11	13	✓	✓	✓	-	-	∞	0.07	11	P
	GRINDER	3	1	13	✓	✓	✓	0.11	0.06	∞	0.74	11	P
	DRINKS COFFER	4	1	13	✓	✓	✓	0.08	0.03	∞	0.27	11	P

PORTABLE APPLIANCE INSPECTION AND TEST RECORD

Suzie Monk Nov 7.

CONTACT NAME & SITE ADDRESS:

Rdmside Event CPTENGA

CONTRACTOR'S TRADING TITLE & ADDRESS:

Rdmside Hall

TEST EQUIPMENT - Make, Model and Ser. N°:

KENTECH KT71

EMPLOYEE UNDERTAKING WORK

NAME (BLOCK CAPITALS)
S. WERTON

SIGNATURE


Room Number (location)	Appliance Description & Make, etc	Identify N°	Class (I, II, etc)	VISUAL CHECKS				ELECTRICAL TESTS				Comments	Date of Check	Pass (P) or Fail (F)
				Fuse Rating (A)	Plug	Lead	App. casing	Earth Bond Test current (A)	Resistance (Ω)	Insulation Resistance MΩ	mA			
	COLD COLD COXER	1	1	13	✓	✓	✓	25	0.11	>20	0.18		3-5-17	P
	BUZZER FRIDGE	2	1	13	✓	✓	✓	25	0.14	>20	0.17		"	P
	BUZZER FREEZER	3	1	13	✓	✓	✓	25	0.11	>20	0.22		"	P
	RICE MAKER 1	4	1	13	✓	✓	✓	25	0.06	>20	0.43		"	P
	RICE MAKER 2	5	1	13	✓	✓	✓	25	0.09	>20	0.71		"	P
	WBT UNIT	6	1	13	✓	✓	✓	25	0.09	>20	3.72		"	P
	CHILLER UNIT	7	1	13	✓	✓	✓	25	0.04	>20	0.28		"	P
	WATER PUMP	8	11	3	✓	✓	✓	+	0.04	>20	0.04		"	P

